

## MONTEREY COUNTY REGIONAL FIRE DISTRICT PREVENTION DIVISION

## GENERATOR SIGN WORDING

P			
Е	BUILDING PERMIT #:	APN:	
S	SITE ADDRESS:		
We have been advised that you are installing an emergency generator at this facility. To assist us with Fire Department Emergency Operations, please review the required wording from the National Electrical Code. The sign must be permanent with 1-inch minimum letters contrasting with the background color. <i>Prior to the Fire Department Final</i> for this project, this sign (or approved alternate) must be posted and maintained at the following location(s):			
☐ Main Exterior Electrical Shut Off ☐ Meter ☐ As follows:			
PLACED ON MAIN PANEL			
, .	THIS SERVICE CONNEC	CTION IS FED BY	AN
	EMERGENCY GENERA	TOR LOCATED A	T

## PLACED ON GENERATOR AT THE STOP SWITCH OR BREAKER ON GENERATOR AND BALL VALVE GAS SHUT OFF WHEN APPLICABLE

(fill in location of system d/c disconnect, inverter and transformer components)

**GENERATOR SHUT OFF** 

For additional information, please contact: Monterey County Regional Fire District (831) 455-1828