

# MONTEREY COUNTY REGIONAL FIRE DISTRICT

19900 Portola Drive Salinas, California 93908  
(831) 455-1828 Fax (831) 455-0646 [www.mcrfd.org](http://www.mcrfd.org)

---



Michael B. Urquides, Fire Chief  
Kevin Kamnikar, Division Chief/Fire Marshal

## **FIRE HYDRANT SPECIFICATIONS**

### All Hydrants:

- 0.9 Coefficient
- Brass construction
- Wet barrel
- Hydrant shut-off valve clearance shall be a minimum of 15 feet from hydrant.
- Minimum 18" vertical clearance from center of lowest outlet to finish grade.
- Minimum 36" horizontal clearance from outside of widest outlet (including landscaping).
- If soil retention is an issue, retaining walls shall be added.
- Hydrants shall be pre-flushed prior to fire department flushing, flow testing & acceptance.

### Commercial Hydrants:

- Two 2-1/2" outlets
- One 4-1/2" outlet

### Residential Hydrants:

- One or Two 2-1/2" outlet(s)  
(minimum of One 2-1/2" outlet)
- One 4-1/2" outlet

*Serving the Northern Salinas Valley, Highway 68 Corridor, Community of Chualar,  
East Garrison, Carmel Valley, Mid Carmel Valley & Santa Lucia Preserve*