



MONTEREY COUNTY REGIONAL FIRE DISTRICT PREVENTION DIVISION

PHOTOVOLTAIC SYSTEM SIGNAGE WORDING

PROJECT NAME: _____

BUILDING PERMIT #: _____

APN: _____

SITE ADDRESS: _____

We have been advised that you are installing a solar panel system at this facility. To assist us with Fire Department Emergency Operations, please review the required wording from the National Electrical Code 690. The sign must be permanent with 1-inch minimum letters contrasting with the background color. *Prior to the Fire Department Final* for this project, this sign (or approved alternate) must be posted and maintained at the following location(s):

- Main Exterior Electrical Shut Off
- Meter
- As follows: _____

**THIS SERVICE CONNECTION IS FED BY A
PHOTOVOLTAIC SYSTEM
LOCATED AT _____**

For additional information, please contact:

Kevin Kamnikar, Division Chief/Fire Marshal
Dorothy Priolo, Deputy Fire Marshal
or
Rick Magno, Inspection Specialist

**Monterey County Regional Fire District
(831) 455-1828**